

REDFIELD WATER QUALITY REPORT – 2009
City of Redfield
626 Main Street; Redfield, SD, 57469
www.redfield-sd.com

Water Quality: Last year, we monitored your drinking water for more than 80 possible contaminants. This document is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to *Environmental Protection Agency (EPA)* and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source: We serve more than 2,800 customers an average of 243,700 gallons of water per day. Our water is surface water that we purchase from another water system. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the City of Redfield public water supply system is medium.

For more information about your water and information on opportunities to participate in public meetings, call (605) 472-4560 and ask for Tom Lesselyoung.

Additional Information: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential users.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, *EPA* prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. *Food and Drug Administration* regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

REDFIELD WATER QUALITY REPORT – 2009

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Redfield public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you

can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2008 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 - December 31, 2008. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).


Terms & Abbreviations used in the attached tables:

- **Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Action Level (AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Treatment Technique (TT):** a required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU.

REDFIELD WATER QUALITY REPORT – 2009

Units:

- MFL: million fibers per liter
- mrem/year: millirems per year (a measure of radiation absorbed by the body)
- NTU: Nephelometric Turbidity Units
- pCi/l: picocuries per liter (a measure of radioactivity)
- ppm: parts per million, or milligrams per liter (mg/l)
- ppb: parts per billion, or micrograms per liter (ug/l)
- ppt: parts per trillion, or nanograms per liter
- ppq: parts per quadrillion, or picograms per liter
- pspm: positive samples per month



REDFIELD WATER QUALITY REPORT – 2009

The City of Redfield public water system purchases water from WEB Water Development Association (EPA ID 1089). WEB Water Development Association’s information on detected contaminates is included in the following table.

2008 Table of Detected Contaminants For Redfield (EPA ID 0277)

Contaminant	Highest Level Detected	Range	Date Last Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contamination
Alpha emitters (Source: 1089)	4.4		04/15/04	15	0	pCi/l	Erosion of natural deposits
Antimony (source: 1089)	0.4		11/19/07	6	6	ppb	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Barium (Source: 1089)	0.053		11/19/07	2	2	ppm	Discharge of drilling wastes; discharge metal refineries; erosion of natural deposits.
Copper	0.5	#Sites> 1.3 AL-0	09/25/06	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Copper (Source 1089)	0.7	#Sites> 1.3 AL - 0	09/25/07	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (Source: 1089)	1.50	1.04 – 1.50	10/07/08	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Lead (Source: 1089)	2	#Sites>15 AL – 0	07/20/07	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits
Lead	19	#Sites>15 AL-1	09/25/06	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate (as Nitrogen) (Source: 1089)	0.3		08/13/08	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Haloacetic Acids (Source: 1089)	17.52	11.1 – 17.52	07/29/08	60	0	ppb	By-product of drinking water chlorination
Haloacetic Acids	8.67		09/23/07	60	0	ppb	By-product of drinking water chlorination
Selenium (Source: 1089)	1.1		11/19/07	50	50	ppb	Discharge from petroleum & metal refineries; erosion of natural deposits; discharge from mines
Total trihalomethanes (Source: 1089)	9.58	5.79 – 9.58	07/29/08	80	0	ppb	By-product of drinking water chlorination.
Total trihalomethanes	4.42		09/23/07	80	0	ppb	By-product of drinking water chlorination
Turbidity (Source: 1089)	0.20	100% samples below 0.3	04/01/08	TT	NA	NTU	Soil runoff. Turbidity is a measurement of the clarity of the water.

**The City of Redfield was granted an asbestos monitoring waiver on 9/5/2001 by The SD Dept. of Environment and Natural Resources. The waiver will expire on December 31, 2010.*

Report Prepared By: Adam Hansen, Finance Officer Please call the WEB Water Development Association, Inc. office if you have questions (1-800-658-3957) or Tom Tollefson WEB Water Development Water Treatment Plant Supt. at 605-229-4749 or 1-800-658-3957.

“In Accordance with Federal law and U.S. Department of Agriculture policy, The City of Redfield is prohibited from discriminating on the basis of race, color, national origin, sex, age, or disability.”
To file a complaint of discrimination, write USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410, or call (800) 795-3272 (voice) or (202) 720-6382 (TDD).”